



General Notes:

1. SDS = self-drilling tapping screw
2. Valley truss design
 - Valley trusses to be spaced at 24" (610mm) O.C.
 - Refer to approved truss drawings for valley design
 - Bottom chord panel point not to exceed 4'0" (1219mm) O.C.
3. The minimum pitch for this detail is 1.5/12 (7.13°)
4. Top chord live load is 20.0 PSF (.96 kN/m²) and top chord dead load is 10.0 PSF (.48 kN/m²).
5. ASCE 7-02 wind 140 MPH (63 m/s) 30' (9144mm) Mean Height, closed building, Exp C, Category II, K_{zt}= 1.0, and a minimum 5 PSF (0.24 kN/m²) top chord dead load.

 **TrusSteel**[®]
Division of ITW Building Components Group, Inc.

www.TrusSteel.com

Florida: 1950 Marley Drive / Haines City, FL 33844 / (800) 755-6001
Missouri: 13389 Lakefront Drive / Earth City, MO 63045 / (800) 326-4102
California: 8351 Rovana Circle / Sacramento, CA 95828 / (800) 877-3678

TrusSteel Valley Connection To Rated Wood Sheeting

ITW Building Components Group, Inc. shall not be responsible for any performance failure in a connection due to a deviation from this detail. Any variation from this detail shall be approved in advance by ITW Building Components Group, Inc.



Standard Detail:
TS026B

Date:
06/21/07

TrusSteel Detail Category:
Valley Set